

## Cable Gland Selector

Cable Type	CABLE SPEC.			GLANDS			ACCESSORIES		
	Conductor Area (mm <sup>2</sup> )	No. Of Cores	Approx. O/D (mmø)	Indoor BW Gland	Indoor / Outdoor CW Gland	Outdoor EIW Gland	Steel L/Nut 439AA-Brass Earth Tag 428ET-	PCP Shroud 401AA-	
1.5	2	2	12.5	20S	20SS	20SS	53	02	
	3	3	13.0	20S	20SS	20SS	53	02	
	4	4	14.0	20S	20S	20S	53	02	
	7	7	15.9	20	20	20	53	03	
	12	12	20.2	25	25	25	55	05	
	19	19	23.2	25	25	25	55	05	
	27	27	27.9	32	32	32	56	05/06	
	37	37	30.6	32	32	32	56	06	
	2.5	2	2	13.6	20S	20S	20S	53	02
		3	3	14.1	20S	20S	20S	53	02
4		4	15.0	20S	20S	20S	53	02	
7		7	17.1	20	20	20	53	03	
12		12	22.4	25	25	25	55	05	
19		19	26.6	25	25	25	55	05	
27		27	30.7	32	32	32	56	06	
37		37	33.8	40	40	40	57	07	
4	2	2	14.7	20S	20S	20S	53	02/03	
	3	3	15.3	20S	20S	20S	53	02/03	
	4	4	16.4	20	20	20	53	03	
6	2	2	15.9	20	20	20S	53	02/03	
	3	3	16.6	20	20	20	53	03	
	4	4	18.7	20	20	20	53	03	
10	2	2	18.0	20	20	20	53	03	
	3	3	19.5	20	20	20	53	03	
	4	4	21.1	25	25	25	55	05	
16	2	2	20.6	25	25	25	55	05	
	3	3	21.8	25	25	25	55	05	
	4	4	23.6	25	25	25	55	05	
25	2	2	24.3	25	25	25	55	05	
	3	3	26.9	32	32	32	56	06	
	4	4	29.1	32	32	32	56	06	
35	2	2	27.9	32	32	32	56	06	
	3	3	29.6	32	32	32	56	06	
	4	4	32.1	40	40	32	57	07	
50	2	2	25.3	25	25	25	55	05	
	3	3	28.4	32	32	32	56	06	
	4	4	31.3	32	32	32	56	06	
70	2	2	28.1	32	32	32	56	06	
	3	3	32.0	32	32	32	56	06	
	4	4	36.8	40	40	40	57	07	
95	2	2	31.9	32	32	32	56	06	
	3	3	36.7	40	40	40	57	07	
	4	4	40.6	50	50	50S	59	09	
120	2	2	35.1	40	40	40	57	07	
	3	3	40.0	50	50	40	59	09	
	4	4	45.8	50	50	50S	59	09	
150	2	2	38.2	40	40	40	57	07	
	3	3	45.1	50	50	50S	59	09	
	4	4	49.9	50	50	50	59	09	
185	2	2	43.3	50	50	50S	59	09	
	3	3	49.3	50	50	50	59	09	
	4	4	54.9	63	63	63S	61	11	
240	2	2	48.3	50	50	50	59	09	
	3	3	54.5	63	63	63S	61	11	
	4	4	61.0	63	63	63	61	11	
300	2	2	52.5	63	63	63	61	11	
	3	3	59.5	63	63	63	61	11	
	4	4	66.5	75	75	75S	63	13	

1kV XLPE ARMoured CABLES TO BS 5467

*The recommendations above are given in good faith but the dimensions of cables may vary with manufacturing tolerances and we advise that the cable diameter is measured where possible before purchasing components.*